

EU DECLARATION OF CONFORMITY

We hereby declare under our sole responsibility that the following products

AMI-1 followed by MM, SM, FM or SS ¹⁾	AMI-2 S ¹⁾	AMI-3 S ¹⁾	MIA ¹⁾	MIA ¹⁾ - FLR (for R290, R1270)	CIA ¹⁾
---	------------------------------	------------------------------	--------------------------	--	--------------------------

1) followed by number indicates size of fitting in inches or in millimeters

comply with the basic requirements of following **EU Directives**:

- **Pressure Equipment Directive 2014/68/EU**

Fluid Group according to PED ²⁾: 1 + 2

For DN ≤ 25	Above listed products are designed and manufactured in accordance with the sound engineering practice (Article 4.3) of a Member State and shall not bear the CE mark.	Conformity assessment: not applicable
For DN > 25	Above listed pressure equipment comply with the requirements of the Pressure Equipment Directive 2014/68/EU.	Conformity assessment: Category I – Modul A (Internal production control)

2) for the full list of refrigerants see Operating Instructions

Applied harmonized standards:

- EN 378-2: 2016 Refrigerating systems and heat pumps - Safety and environmental requirements. Parts 2: Design, construction, testing, marking and documentation.
- EN 12178: 2016 Refrigerating systems and heat pumps – Liquid level indicating devices – Requirements, testing and marking.

Signed for and on behalf of Emerson Climate Technologies GmbH:



Matthew Irons (Vice-President Engineering)
 Aachen, November 24, 2022